

Presenters

- Todd Walsh
- Enterprise Applications Analyst / Project Manager
- Chelan County Public Utility District
- Telephone: (509) 699-1652
- E-mail: todd.walsh@chelanpud.org
- Ray Hahne
- Senior Maximo Consultant / Project Manager
- Total Resource Management, Inc (TRM)
- Alexandria, Virginia
- Telephone: (509) 630-5062
- E-mail: <u>ray.hahne@trmnet.com</u>
- Maryann Wood
- Systems Support Coordinator
- Chelan County Public Utility District
- Telephone: (509) 661-4004
- E-mail: todd.walsh@chelanpud.org



Presentation Topics

- Chelan PUDs Asset Management Program
- What are condition assessments
- Using Maximo for condition assessments
- Condition assessment reporting



About Chelan PUD



Powerhouses:

Rocky Reach: ~1300MW, 11 Units,

1967

Rock Island: ~640MW, 19 units,


1933/1979

Chelan: ~65MW, 2 units,


1927

Stehekin: ~850kW, 1 hydro, 3 diesel,


1963



Asset Management Model









HydroAMP Asset Management Standards



About us

Contact us



 Centre for Energy Advancement through Technological Innovation

Now Optimized for Mobile and Tablet Use!





Login

hydroAMP Application & Guides

Steering Committee Portal

Hydropower Asset Condition Assessments




Successful strategic planning for capital investments in existing hydropower facilities requires consideration and the balancing of many factors, including the risks and consequences of equipment failure. The hydropower community has long recognized the importance of accurate assessments of equipment condition in order to make informed and sound capital investment planning and management decisions. Seeking to improve the evaluation and documentation of hydroelectric equipment condition, industry leaders have partnered to create the Hydropower Asset Management Partnership (hydroAMP). As part of CEATI's Hydraulic Plant Life Interest Group, which is

comprised of over 60 hydroelectric utilities, the hydroAMP Steering Committee is managing hydroAMP for its current users by assisting in its continued development and guiding its future enhancements.



First Attempt - using Asset Main Screen



Problem: Did not record the history of Asset Health



Condition (Asset Health) Assessments

- Monitoring is a specific reading
- Assessment is using the other operating information to assign scores that represent the current condition of different attributes
 - Age
 - Maintenance History
 - Physical Inspection
- We start with a Tier 1 Assessment and conduct a Tier 2 assessment if more information is needed to prioritize any necessary maintenance
 - Tier 1: Relies on operational history and information gathered during routine maintenance
 - Tier 2: Additional tests and inspections if needed to determine urgency




Condition Index Scoring

Condition Index	
8 to 10	Asset expected to continue operating under normal conditions. Continue current O&M and repeat condition assessment on normal frequency.
5 to 8	Medium level of confidence the asset will continue operating under normal conditions. Continue current O&M. Consider Tier 2 test to further evaluate risks. Minor maintenance may be necessary.
2 to 5	Asset may not perform normally. Expect restricted operation and/or non-routine maintenance. Perform Tier 2 tests.
0 to 2	Expect significant operation restrictions and/or extensive non-routine maintenance. Perform Tier 2 test. Evaluate replacement.




Use Meters Instead - New Meter Type and Groups





Custom Condition Assessment Screens






Input Sheets with Scoring Definitions


	Ph	nysical Inspection:										
3		No physical deterioration is observed										
2	2 Physical deterioration is more than cosmetic, but has not yet compromised physical/structural integrity											
1	1 Physical deterioration is significant though equipment is still functional											
C	0 Physical deterioration has yielded low confidence in physical or structural integrity											
	Op	erational Performance:										
3		Performance is normal and meets original design criteria										
2		Performance is adequate, and meets original design criteria but is less efficient or effective than when originally installed										
2 1		Performance is adequate, and meets original design criteria but is less efficient or effective than when originally installed Performance is significantly affected or design is inadequate for current function										



Start a New Assessment




Condition Assessment Quality





Decay Rate Reporting



Static Reporting

Asset Condition Report

As	set Number	Description	Priority	Maint Cost	Install Date	Est. ServiceLife	Remaining Service Life	Con. Index	Location
			1	166,685.60	8/28/09	50.00	44.09	8.80	25773
			1	96,309.69	5/16/03	20.00	7.81	7.10	25777
			1	25,632.69	9/25/09	25.00	19.16	10.00	25779
			1	22,396.43	9/25/09	50.00	44.16	10.00	25779
			1	54,992.83	6/13/03	50.00	40.00	7.60	31474
			2	54.45	1/1/09	50.00	43.44	10.00	25775

